

2019 Water Quality Report

Glasgow Water Company - Water Testing Performed in 2018

PWS ID# KY0050929

Water Quality Report

This report is designed to inform the public about the quality of water and services provided by the Glasgow Water Company (GWC). The GWC operates a State Certified Microbiology Laboratory staffed with Class IV Water Treatment Plant Operators and Lab Analysts. Our experienced and accredited personnel analyze tests on water samples 365 days a year to assure water safety and quality. These samples are taken from the treatment process as well as from various sites within the distribution system. We would like the public to be assured that we will continue to monitor, improve, and protect the water system and deliver a high quality product direct to the tap. Water is the most indispensable product in every home, and we ask everyone to help us in our efforts to protect the water source.

The GWC is the 14th largest water utility in the State of Kentucky among nearly 500 utilities. The GWC has a service area encompassing 444 square miles that serves the City of Glasgow, Barren County, and portions of Allen County and Edmonson County. The GWC maintains 884 miles of water mains serving 17,250 water customers and 144 miles of sewer mains serving 6,250 wastewater customers. The GWC also provides wholesale water service to four surrounding utilities including the City of Edmonton (Metcalfe County), Allen County Water District, Fountain Run Water District, and Caveland Environmental Authority. On average GWC operations distribute over 2.8 billion gallons of water and treat over 835 million gallons of waste water annually.



Barren River Lake Water Treatment Plant, Lucas KY

GWC Receives Microbial AWOP Champion Award

GWC's Barren River Lake Water Treatment Plant (WTP) recently earned recognition as the State's top drinking WTP for microbial removal and three-year compliance record performance. This is the State's top award for WTP quality. The Area-Wide Optimization Program (AWOP) outlined by the U.S. Environmental Protection Agency establishes water quality standards that exceed minimum state and federal requirements through optimized filtration plant performance. The AWOP approach provides an increased and sustainable level of public health protection to consumers. This is the 13th consecutive year the GWC has achieved the AWOP designation. Our staff is critical to our success and our community is fortunate to have dedicated professionals working to ensure that GWC services remain affordable and of extremely high quality. It is our people that make us an industry leader and an organization for which our community can be proud.



2018 Microbial AWOP
Champion

Customer Notifications

The GWC can provide customers with time-sensitive information in a variety of communication formats however you specify (such as text message, e-mail, and mobile, home or business phone). **The GWC respects your privacy and will only notify customers in situations such as Boil Water Advisories, emergencies and planned outages.**



To sign up visit www.glasgowh2o.com and click on the Instant Notifications link. If you do not have internet access or need assistance signing up contact us at 270-651-3727.

**DID YOU
KNOW?**



**YOU CAN PAY YOUR
WATER BILL
ONLINE.**

**IT IS QUICK, EASY,
AND SECURE.**

www.glasgowh2o.com

WATER SOURCE INFORMATION

The GWC operates two water treatment plants, both treating surface water. They are the Barren River Lake Water Treatment Plant (source plant A) located in Lucas, and the Beaver Creek Water Treatment Plant (source plant B) located north of Glasgow. The Barren River Lake Water Treatment Plant's raw water source is Barren River Lake while the Beaver Creek Water Treatment Plant draws raw water from Beaver Creek.

A source water assessment has been completed. The Barren River Lake has one KPDES permitted discharger, an under-ground storage tank, agricultural chemical users and oil and gas wells that could be possible sources of contamination. The Beaver Creek Plant has two bridges, several oil and gas wells, one KPDES permitted discharger, an underground storage tank and agricultural chemical users upstream and in proximity of its intake. The final source water assessment with the system's susceptibility to potential sources of contamination is available for review at the Barren River Area Development District (BRADD) office located at 177 Graham Avenue, Bowling Green, Kentucky.

HOME PLUMBING AND LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 1-800-426-4791 or at www.epa.gov/safewater/lead.

Secondary Contaminants

Secondary Contaminants do not have a direct impact on the health of consumers and are not required in this Water Quality Report. They are being included to provide additional information about the quality of your drinking water. The data displayed below represents the highest value from either source plant A or B.

Secondary Contaminant	Maximum Allowable Level	Report Level
Aluminum	0.05 to 0.2 ppm	0.04 ppm
Copper	1.0 ppm	0 ppm
Iron	0.3 ppm	0 ppm
Zinc	5 ppm	0 ppm
pH	6.5 to 8.5	7.9

Sodium

There is no MCL or MCLG for sodium. Monitoring is required to provide information to consumers concerned about sodium intake for dietary reasons. Sodium is a naturally occurring element found in water and soil as a result of erosion of natural deposits.

	EPA Guidance Level	Range of Detection
Sodium (ppm)	20	3.23 to 6.53



Fluoride Regulation (added for dental health)

Kentucky statute (902 KAR 115:010) requires water treatment plants to dose fluoride within a range between 0.6 to 1.2 ppm. GWC's goal is to maintain a 0.8 ppm residual at all times to ensure compliance with Kentucky regulations while keeping an operating tolerance on the low range of the scale.

	Average	Range of Detection
Fluoride (added for dental health) (ppm)	0.8	0.57 to 1.07

Regulated Contaminants in the Water Supply

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline 1-800-426-4791.

Contaminants that may be present in source water include:

Microbial Contaminants. Examples include viruses and bacteria that may come from wildlife, agricultural livestock operations, septic systems, and waste water treatment plants.

Inorganic Contaminants. Examples include salts and metals, that can be naturally occurring or result from storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and Herbicides. These may come from a variety of sources such as agriculture, storm water runoff, and residential use.

Organic Chemical Contaminants. These include synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, storm water runoff, and septic systems.

Radioactive Contaminants. These can be naturally occurring or be the result of oil and gas production and mining activities.

Regulated Contaminant Test Results

The data presented in this report is from the most recent testing performed in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Source "A" is the Barren River Lake Water Treatment Plant and Source "B" is the Beaver Creek Water Treatment Plant.**

Maximum Contaminant Levels (MCL's) are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Contaminant [code] (units)	Allowable Levels	Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Contamination
Turbidity (NTU) TT * Representative Samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples	A B	0.093 0.097	100 100	NO	Soil runoff

Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
----------------------------	-----	------	--------	--------------	--------------------	----------------	-----------	--------------------------------

Inorganic Contaminants

Barium [1010] (ppm)	2	2	A B	0.024 0.027	0.024 to 0.024 0.027 to 0.027	Feb-18	NO	Drilling wastes; metal refineries; erosion of natural deposits
Copper [1022] (ppm) Sites exceeding action level 0	AL = 1.3	1.3		0.127 (90th percentile)	0.0095 to 0.293	Aug-16	NO	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	A B	0.7 0.7	0.7 to 0.7 0.7 to 0.7	Feb-18	NO	Water additive which promotes strong teeth
Lead [1030] (ppb) Sites exceeding action level 0	AL = 15	0		0 (90th percentile)	0 to 2	Aug-16	NO	Corrosion of household plumbing systems
Nitrate [1040] (ppm)	10	10	A B	2.2 2.3	1.7 to 2.2 1.7 to 2.3	Feb-17	NO	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits

Disinfectants/Disinfection Byproducts and Precursors

Total Organic Carbon (ppm) (report level = lowest avg. range of monthly ratios)	TT*	N/A	A B	1.85 2.47	1.60 to 2.78 1.48 to 3.87	2018	NO	Naturally present in environment
---------------------------------------------------------------------------------	-----	-----	--------	--------------	------------------------------	------	-----------	----------------------------------

*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average of the monthly ratios must be 1.00 or greater for compliance.

Chlorine (ppm)	MRDL = 4	MRDLG = 4		1.34 (highest average)	0.24 to 2.05	2018	NO	Water additive used to control microbes
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A		48 (average)	14 to 60 (range of individual sites)	2018	NO	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [Total trihalomethanes]	80	N/A		56 (average)	14.6 to 55.4 (range of individual sites)	2018	NO	Byproduct of drinking water disinfection

Unregulated Contaminants (UCMR 4)

Contaminant	Source	Average (ppb)	Range (ppb)	Date of Sample
HAA5	A/B	27.648	8.57 to 46.2	Oct-18
HAA6Br	A/B	5.303	2.37 to 9.44	Oct-18
HAA9	A/B	32.719	11.4 to 49	Oct-18

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those that EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

Additional copies of this Water Quality Report are available at our main office located at 301 West Main Street or by visiting our website at www.glasgowh2o.com. If you have any questions about the information contained within this report, please contact Scott Young, General Manager, or Tim Smiley, CCR Contact, at 270-651-3727. The Glasgow Water and Sewer Commission's regular monthly meetings are held on the second Thursday of each month at 3:00 P.M. CST at the Glasgow Water Company office located at 301 West Main Street.

Water Quality Data

In the Water Quality Data Table, you may find terms or abbreviations that are unfamiliar. To help you better understand the results, the following definitions are provided. Some or all of these definitions may be found in this report:

MCL = Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TT = Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

AL = Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Turbidity = A measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

NTU = Nephelometric Turbidity Unit - Measures cloudiness of water.

MRDL = Maximum Residual Disinfectant Level - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG = Maximum Residual Disinfectant Level Goal - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

BDL = Below Detection Levels - Laboratory analysis indicates that the contaminant is not present.

ND = Not Detected - Indicates that the substance was not found by laboratory analysis.

Range of Detection = This is the lowest and highest levels of detection.

N/A = Not Applicable - Does not apply.

ppm = Parts per million - Milligrams per liter, (mg/L) - Corresponds to one penny in \$10,000.

ppb = Parts per billion - Micrograms per liter, (µg/L) - Corresponds to one penny in \$10,000,000.

TOC = Total Organic Carbon - Measure of the total amount of organic matter in water.

NOTICE: IMPORTANT INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 800-426-4791. Another Source for information on water quality is the Kentucky Division of Water's website: www.water.ky.gov/dw/



Accomplishments

2006-2018 USEPA Area Wide Optimization Program (AWOP) recognition – Kentucky Energy and Environment Cabinet (KYEEC).

2018 Microbial AWOP Champion Award – KYEEC.

2018 Excellence in Energy Leadership Award – KYEEC.

2018 Environmental Project of the Year – American Public Works Association of Kentucky.

2018 Engineering Excellence Grand Award – American Council of Engineering Companies of Kentucky.

2018 & 2012 Kentucky's Best Tasting Water Award – Kentucky Rural Water Association.

2017 Wastewater Treatment Plant of the Year – Kentucky Water and Wastewater Operator's Association.

2016 Governor's Safety and Health Award – Kentucky Labor Cabinet.

2015 Water Treatment Plant of the Year – Kentucky Water and Wastewater Operator's Association.

2014 Wooden Bucket Award – Kentucky Rural Water Association.

WE HAVE MOVED

OUR OFFICE IS NOW LOCATED AT:
301 WEST MAIN STREET GLASGOW, KY 42141

Customer Service

Regular Business Hours:

Monday - Friday, 8:00 a.m. - 4:30 p.m.

Service, Billing, Emergencies:

(270) 651-3727

Bill Payment Options

Online:

www.glasgowh2o.com

By Phone:

(270) 651-3727

In Person, Drive Thru or Drop Box (After hours):

GWC Office, 301 West Main Street, Glasgow, KY 42141

By Mail:

P.O. Box 819, Glasgow, KY 42142-0819

Local Banks (Payment Drop Off):

- BB&T •Citizens First Bank •Edmonton State Bank
- Limestone Bank •Monticello Bank •Peoples Bank
- South Central Bank •US Bank

ACH (Automatic Bank Draft):

Payment is automatically deducted from your checking or savings account on your due date.

OUR MISSION:

To provide the highest quality water and wastewater services at the lowest possible cost, while continuing our commitment to meet the needs of today's customers as well as future generations.



Board of Commissioners:

Jerry Botts, Chairman

Buddy Underwood, Vice Chairman

Woodford Gardner, JR., Secretary-Treasurer

Harold Armstrong, Mayor-Member

Brad Groce, Council Representative

Management Staff:

Scott Young, General Manager

Billy Carver, Operations Manager

Clint Harbison, Engineering Manager

Jeffrey Reed, Finance/Customer Service Manager

Bryan Crabtree, Maintenance Superintendent

Tim Smiley, WTP Superintendent

Jacob Billingsley, WWTP Superintendent

Lance Crimmins, Safety and Risk Manager